



City of Largo Agenda Item 14

Meeting Date
10/16/18

Presenter:

Department:

TITLE:

AWARD OF BID NO. 19-B-644, SANITARY SEWER, RECLAIMED WATER AND STORMWATER REPAIR, TO ROWLAND, INC., GATOR GRADING AND PAVING, LLC, QRC, INC., AND ALL AMERICAN CONCRETE, INC.

Engineering Services requests award of Bid No. 19-B-644, Sanitary Sewer, Reclaimed Water and Stormwater Repair annual purchase agreement (APA), to the four recommended bidders. The City performs contract rehabilitation and repair of sanitary sewer, reclaimed water, and storm sewer systems through the use of an APA with multiple contractors for trenchless pipe rehabilitation, manhole rehabilitation, and traditional excavation, repair and restoration. This APA is for traditional excavation, repair and restoration, which includes sanitary sewer, reclaimed water, and storm sewer pipe replacement, and other underground utility repair and replacement.

The four recommended bidders are:

- Rowland, Inc.
- Gator Grading and Paving, LLC
- QRC, Inc.
- All American Concrete, Inc.

By awarding the APA to the four recommended bidders, the City will be able to obtain all of the services included in the bid and will benefit from the timely completion of work.

(Continued on Page 2)

Budgeted Amount:	<input type="text" value="\$8,932,100.00"/>	Budget Page No(s):	<input type="text" value="177, 188, 192, 293, Itemized 251"/>	Available Amount:	<input type="text" value="\$8,932,100.00"/>	Expenditure Amount:	<input type="text" value="\$0.00"/>
-------------------------	---	---------------------------	---	--------------------------	---	----------------------------	-------------------------------------

Additional Budgetary Information:

Funding Source(s):	<input type="text" value="Stormwater, Wastewater"/>	Sufficient Funds Available:	<input checked="" type="radio"/> Yes <input type="radio"/> No	Budget Amendment Required:	<input type="radio"/> Yes <input checked="" type="radio"/> No	Source:	<input type="text" value="N/A"/>
---------------------------	---	------------------------------------	--	-----------------------------------	--	----------------	----------------------------------

City Attorney Reviewed:	<input type="radio"/> Yes <input type="radio"/> No <input checked="" type="radio"/> N/A	Advisory Board Recommendation:	<input type="radio"/> For <input type="radio"/> Against <input checked="" type="radio"/> N/A	Consistent With:	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="text" value="Strategic Plan"/>
--------------------------------	---	---------------------------------------	--	-------------------------	---	---

Potential Motion/ Direction Requested:

Staff Contact:	<input type="text" value="Charles Mura, P.E., Senior Engineer"/>	<input type="text" value="x4414"/>	<input type="text" value="cmura@largo.com"/>
-----------------------	--	------------------------------------	--

Attachments:

FY 2019 budgeted items considered for this APA are:

Stormwater		Dept
\$150,000	Stormwater APA Repairs	EN
\$132,100	Stormwater Repairs	PW
\$100,000	Stormwater Pipe Replacement	PW
Wastewater		Dept
\$250,000	Sanitary Sewer Repair APA	EN
\$4,000,000	Hermine SSO Prevention	ES
\$4,200,000	LS-2 I&I Abatement	ES
\$100,000	Reclaimed Water Repair/Maintenance	ES
\$8,932,100	Total	

The intended use of the Hermine SSO Prevention funding is for Inflow and Infiltration (I &I) and hydraulic bottleneck corrective actions within all five of the evaluation areas specifically Lift Station sanitary sewer basins 12,16, 20, 28 and 39. Similar to the work accomplished with FY 2018 funding, Engineering Services will issue APA work orders for gravity pipe repair, replacement and reconfiguration.

Likewise, the intended use of the Lift Station 2 I&I abatement funding will also be for corrective actions within Lift Station 2 sub-basin 1 for APA work orders for gravity pipe repair, replacement and reconfiguration.

Funds will not be expended unless a specific project/scope is assigned to a contractor.

